

# 福島県原子力発電所周辺環境放射能測定結果（速報）

平成29年度（平成29年8月）測定分

## 1 測定項目

### （1）空間放射線

項目	地点数	測定頻度	実施機関
空間線量率	39	連続	環境創造センター
空間積算線量	64（結果は3ヵ月毎）	3ヵ月積算	

### （2）環境試料

区分	試料名	地点数	採取頻度	採取回数 (8月)	測定試料数(8月)						実施機関	
					全β 連続 全α全β	γ	<sup>131</sup> I	<sup>3</sup> H	Sr	Pu		Am,Cm
大気	大気浮遊じん	17	毎月	1		17						環境創造センター
		9		1		9						
		16	毎週	4		64						
降下物	降下物	10	毎月	1		10						
陸土表土	土	15	年2回	0		0						
			年1回	0				0	0	0		
陸水上水	水	11	年4回	0		0		0				
			年1回	0				0	0			
海水	水	6(*1)	毎月	1	6	6		6	6	6		
		2(*2)	年4回	1	2	2		2				
			年1回	0				0	0			
海底土	海底土	6(*1)	年4回	1		6			6	6		
		2(*2)	年4回	1		2						
			年1回	0				0	0			
指標植物	松葉	15	年4回	1		15	15					

\*1 東京電力ホールディングス（株）福島第一原子力発電所周辺海域

\*2 東京電力ホールディングス（株）福島第二原子力発電所周辺海域

## 2 測定項目（比較対照地点調査）

### （1）空間放射線

項目	地点数	測定頻度	実施機関
空間線量率	3	連続	環境創造センター

### （2）環境試料

区分	試料名	地点数	採取頻度	採取回数 (8月)	測定試料数(8月)						実施機関	
					全β	γ	<sup>131</sup> I	<sup>3</sup> H	Sr	Pu		Am,Cm
大気	大気浮遊じん	7	毎月	1		7						環境創造センター
	大気中水分	1		1			1					
降下物	降下物	2	毎月	1		2						
陸土表土	土	7	年1回	0		0			0	0	0	
陸水上水	水	2	年1回	0		0		0	0	0		
海水	水	1	年1回	0	0	0		0	0	0		
海底土	海底土	1	年1回	0		0			0	0		
指標植物	松葉	5	年4回	1		5	5					

（注）次ページ以降の黄色網掛け部分が、今回の公表分です。





No.	測定年月		測定項目		測定地点名		H29.4		5		6		7		8		9		10		11		12		H30.1		2		3		
	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	線量率	測定時間	
28	124 (143)	720	127 (140)	744	125 (142)	720	127 (150)	744	124 (143)	744	125 (142)	720	127 (150)	744	124 (143)	744															
29	84 (98)	720	86 (102)	744	84 (99)	720	86 (120)	744	84 (100)	744	86 (120)	720	86 (120)	744	84 (100)	744															
30	173 (181)	720	173 (181)	744	170 (183)	720	171 (189)	744	166 (179)	742	170 (183)	720	171 (189)	744	166 (179)	742															
31	112 (125)	720	112 (124)	744	109 (120)	720	110 (133)	740	106 (117)	744	109 (120)	720	110 (133)	740	106 (117)	744															
32	890 (912)	720	890 (915)	744	884 (905)	720	893 (924)	744	877 (905)	744	884 (905)	720	893 (924)	744	877 (905)	744															
33	1,350 (1,420)	720	1,370 (1,450)	744	1,350 (1,410)	720	1,330 (1,430)	744	1,280 (1,370)	744	1,350 (1,410)	720	1,330 (1,430)	744	1,280 (1,370)	744															
34	162 (172)	720	162 (177)	744	161 (179)	720	161 (189)	744	156 (168)	744	161 (179)	720	161 (189)	744	156 (168)	744															
35	135 (147)	720	135 (152)	744	132 (148)	720	133 (162)	744	126 (144)	744	132 (148)	720	133 (162)	744	126 (144)	744															
36	273 (286)	720	275 (288)	744	272 (283)	720	272 (293)	744	261 (276)	744	272 (283)	720	272 (293)	744	261 (276)	744															
37	46 (66)	720	46 (72)	744	46 (66)	720	47 (88)	741	45 (62)	744	46 (66)	720	47 (88)	741	45 (62)	744															
38	234 (249)	720	236 (251)	744	239 (258)	720	232 (255)	739	225 (245)	744	239 (258)	720	232 (255)	739	225 (245)	744															
39	170 (185)	720	171 (187)	744	169 (181)	720	163 (193)	740	157 (169)	744	169 (181)	720	163 (193)	740	157 (169)	744															

(注) 1 No.の網掛け部分は東京電力株式会社福島第一原子力発電所から半径5km未満の地域

2 \*1 可搬型モニタリングポストによる測定

3 \*2 空間線量率の測定はモニタリングポスト (NaIシンチレーション検出器、単位：ナノグレイ/時) により行ったが、概ね10,000nGy/h (10μGy/h)を超えた場合は、

併設している高線量用モニタリングポスト (電離箱検出器、単位：ナノグレイ/時) の測定値で補完した。

5-1-2 空間積算線量

(単位 mGy)

No.	測定地点名	測定項目	H29. 4. 13 ~H29. 7. 13					
			積算線量	測定 日数	積算線量	測定 日数	積算線量	測定 日数
1	いわき市 石森		0.23 (0.22)	91				
2	いわき市 西倉		0.28 (0.28)	91				
3	いわき市 大野		0.22 (0.22)	91				
4	いわき市 福岡		0.25 (0.24)	91				
5	いわき市 大久保		0.23 (0.23)	91				
6	いわき市 末統		0.33 (0.33)	91				
7	いわき市 上小川		0.36 (0.35)	91				
8	いわき市 志田名		0.41 (0.41)	91				
9	いわき市 小白井		0.22 (0.22)	91				
10	田村市 場々		0.39 (0.39)	91				
11	田村市 古道		0.25 (0.25)	91				
12	田村市 岩井沢		0.21 (0.21)	91				
13	広野町 下浅見川		0.23 (0.22)	91				
14	広野町 篝平		0.28 (0.28)	91				
15	檜葉町 山田岡		0.22 (0.22)	91				
16	檜葉町 乙次郎		0.28 (0.27)	91				
17	檜葉町 井出		0.28 (0.28)	91				
18	檜葉町 上繁岡		0.43 (0.43)	91				
19	富岡町 太田		0.58 (0.58)	91				
20	富岡町 赤木		0.50 (0.49)	91				
21	富岡町 小良ヶ浜		4.1 (4.1)	91				
22	富岡町 夜の森北		1.8 (1.8)	91				

(単位 mGy)

No.	測定地点名	測定項目	H29. 4. 13 ～H29. 7. 13					
			積算線量	測定 日数	積算線量	測定 日数	積算線量	測定 日数
23	富岡町	上手岡	0.79	( 0.79 )	91			
24	川内村	三ツ右	0.69	( 0.68 )	91			
25	川内村	貝ノ坂	1.0	( 1.0 )	91			
26	川内村	五枚沢	0.35	( 0.35*1)	91			
27	川内村	上川内	0.22	( 0.22 )	91			
28	大熊町	大川原	0.45	( 0.44 )	91			
29	大熊町	旭ヶ丘	0.53	( 0.52 )	91			
30	大熊町	野上	3.8	( 3.8 )	91			
31	大熊町	熊川	8.3	( 8.2 )	91			
32	大熊町	大野	10	( 9.9 )	91			
33	大熊町	夫沢	25	( 25 )	91			
34	大熊町	湯の神	2.6	( 2.6 )	91			
35	大熊町	長者原	7.3	( 7.2 )	91			
36	双葉町	清戸迫	1.6	( 1.6 )	91			
37	双葉町	郡山	1.1	( 1.1 )	91			
38	双葉町	長塚	3.3	( 3.2 )	91			
39	浪江町	井手	17	( 17 )	91			
40	浪江町	請戸	0.34	( 0.33 )	91			
41	浪江町	小野田	1.2	( 1.2 )	91			
42	浪江町	幾世橋	0.34	( 0.34 )	91			
43	浪江町	疋宿	0.75	( 0.74 )	91			
44	浪江町	皇曾根	9.4	( 9.3 )	91			

(単位 mGy)

No.	測定地点名	測定項目	H29. 4. 13 ～H29. 7. 13					
			積算線量	測定 日数	積算線量	測定 日数	積算線量	測定 日数
45	浪江町 津島		4.1 ( 4.1 )	91				
46	葛尾村 天放		0.44 ( 0.44 )	91				
47	葛尾村 落合		0.57 ( 0.56 )	91				
48	葛尾村 野行		3.4 ( 3.4 )	91				
49	南相馬市 浦尻		0.27 ( 0.26 )	91				
50	南相馬市 耳谷		0.31 ( 0.31 )	91				
51	南相馬市 川房		1.3 ( 1.3 )	91				
52	南相馬市 関場		0.59 ( 0.58 )	91				
53	南相馬市 高		0.25 ( 0.25 )	91				
54	南相馬市 大木戸		0.20 ( 0.19 )	91				
55	南相馬市 晝浜		0.16 ( 0.16 )	91				
56	南相馬市 大原		0.40*2 ( 0.39*2)	91				
57	南相馬市 川子		0.29 ( 0.29 )	91				
58	飯館村 蘇平		1.0 ( 0.98 )	91				
59	飯館村 長泥		3.9 ( 3.9 )	91				
60	飯館村 飯樋		0.69 ( 0.68 )	91				
61	飯館村 白石		1.3 ( 1.2 )	91				
62	飯館村 草野		1.1 ( 1.1 )	91				
63	川俣町 山木屋坂下		1.1 ( 1.1 )	91				
64	川俣町 山木屋		0.38 ( 0.38 )	91				

注) 1 ( ) 内は90日換算値

2 No. の網掛け部分は東京電力株式会社福島第一原子力発電所から半径5km未満の地域

3 \*1 収納箱が移動されていたので参考値

4 \*2 収納箱が倒壊していたので参考値





No.	測定地名	測定項目	H29.4		5		6		7		8		9		10		11		12		H30.1		2		3		
			測定値	測定時間	測定値	測定時間	測定値	測定時間	測定値	測定時間	測定値	測定時間	測定値	測定時間	測定値	測定時間	測定値	測定時間	測定値	測定時間	測定値	測定時間	測定値	測定時間	測定値	測定時間	
9	大瀬町 たつとぎ次	全アルファ	0.018	720	0.021	732	0.016	684	0.021	744	0.011	744															
		放射能	(0.11)	(0.13)	(0.073)	(0.16)	(0.070)	(0.070)	(0.070)	(0.070)	(0.070)	(0.070)	(0.070)														
10	双葉町 まおりやま山	全アルファ	0.015	720	0.022	732	0.014	654	0.020	744	0.010	744															
		放射能	(0.073)	(0.11)	(0.068)	(0.13)	(0.068)	(0.13)	(0.068)	(0.13)	(0.068)	(0.068)	(0.068)														
11	浪江町 幾上世橋	全アルファ	0.023	720	0.033	744	0.025	720	0.028	672	0.016	744															
		放射能	(0.088)	(0.20)	(0.14)	(0.15)	(0.14)	(0.15)	(0.14)	(0.15)	(0.091)	(0.091)	(0.091)														
12	浪江町 大船ダム	全アルファ	0.032	708	0.038	744	0.036	624	0.043	744	0.030	744															
		放射能	(0.14)	(0.14)	(0.14)	(0.14)	(0.14)	(0.14)	(0.14)	(0.14)	(0.21)	(0.21)	(0.21)														
13	鶴尾村 夏のお湯	全アルファ	0.061	720	0.068	732	0.055	672	0.060	732	0.031	744															
		放射能	(0.34)	(0.37)	(0.32)	(0.28)	(0.32)	(0.28)	(0.32)	(0.28)	(0.18)	(0.18)	(0.18)														
14	藤相馬市 いずみさか	全アルファ	0.020	708	0.025	744	0.018	660	0.024	744	0.012	744															
		放射能	(0.095)	(0.10)	(0.080)	(0.11)	(0.080)	(0.11)	(0.080)	(0.11)	(0.061)	(0.061)	(0.061)														
15	藤相馬市 いばき	全アルファ	0.021	720	0.026	744	0.016	720	0.022	732	0.008	744															
		放射能	(0.12)	(0.13)	(0.11)	(0.11)	(0.11)	(0.11)	(0.11)	(0.11)	(0.052)	(0.052)	(0.052)														
16	飯沼村 いとださか	全アルファ	0.037	720	0.042	744	0.035	720	0.036	732	0.040	744															
		放射能	(0.37)	(0.42)	(0.33)	(0.36)	(0.33)	(0.36)	(0.33)	(0.36)	(0.18)	(0.18)	(0.18)														
17	川俣町 山木	全アルファ	0.016	720	0.023	744	0.021	708	0.016	732	0.006	744															
		放射能	(0.096)	(0.16)	(0.14)	(0.14)	(0.14)	(0.14)	(0.14)	(0.14)	(0.027)	(0.027)	(0.027)														

注) 1 No.の欄付け部分は東京電力株式会社福島第一原子力発電所から半径500m圏の区域

No.	地点名	採取期間	核種濃度 (mBq/m <sup>3</sup> )																
			<sup>51</sup> Cr	<sup>51</sup> Mn	<sup>58</sup> Co	<sup>59</sup> Fe	<sup>60</sup> Co	<sup>90</sup> Zr	<sup>95</sup> Nb	<sup>106</sup> Ru	<sup>134</sup> Cs	<sup>137</sup> Cs	<sup>144</sup> Ce						
1	いわき市 小川 (連続ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.004	ND	ND		
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.005	ND	ND	
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.007	ND	ND	
2	田村市 都路馬洗戸 (連続ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.004	ND	ND	
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.004	ND	ND	
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.004	ND	ND	
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
3	広野町 小籠平 (連続ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.004	ND	ND	ND	
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.010	ND	ND	ND	
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.007	ND	ND	ND	
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.005	ND	ND	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
4	榑葉町 木戸ダム (連続ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.18	ND	ND	ND	
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.29	ND	ND	ND	
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.15	ND	ND	ND	
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.17	ND	ND	ND	
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.021	0.15	ND	ND	ND
5	榑葉町 繁岡 (連続ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.006	0.026	ND	ND	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.005	0.035	ND	ND	ND
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.007	0.029	ND	ND	ND
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.047	ND	ND	ND	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.027	0.027	ND	ND	ND
6	富岡町 富岡 (連続ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.006	0.006	ND	ND	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.005	0.035	ND	ND	ND
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.007	0.029	ND	ND	ND
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.047	ND	ND	ND	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.027	0.027	ND	ND	ND
7	川内村 下川内 (連続ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.006	0.006	ND	ND	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.011	0.011	ND	ND	ND
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.008	0.008	ND	ND	ND
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.012	0.012	ND	ND	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.008	0.008	ND	ND	ND
8	大藤町 大野 (連続ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.006	0.044	ND	ND	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.006	0.050	ND	ND	ND
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.010	0.061	ND	ND	ND
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.009	0.066	ND	ND	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.031	0.031	ND	ND	ND
9	大藤町 大沢 (連続ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.024	0.17	ND	ND	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.017	0.12	ND	ND	ND
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.013	0.096	ND	ND	ND
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.019	0.13	ND	ND	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.026	0.20	ND	ND	ND



No.	地点名	採取期間	核種濃度 (mBq/m <sup>3</sup> )														
			<sup>51</sup> Cr	<sup>51</sup> Mn	<sup>58</sup> Co	<sup>59</sup> Fe	<sup>60</sup> Co	<sup>90</sup> Zr	<sup>99</sup> Tc	<sup>100</sup> Ru	<sup>134</sup> Cs	<sup>137</sup> Cs	<sup>144</sup> Ce				
19	いわさき市 下福苑 (リアルタイム ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
20	いわさき市 川前 (リアルタイム ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
21	大瀬町 向畑 (リアルタイム ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.065	0.44	ND	ND	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.047	0.34	ND	ND	ND
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.15	ND	ND	ND	ND
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.047	0.40	ND	ND	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.062	0.63	ND	ND	ND
22	双葉町 山田 (リアルタイム ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.13	ND	ND	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.19	ND	ND	ND
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.15	ND	ND	ND
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.18	ND	ND	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.048	0.22	ND	ND	ND
23	双葉町 新山 (リアルタイム ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.15	ND	ND	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.26	ND	ND	ND
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.20	ND	ND	ND
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.046	0.21	ND	ND	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.17	ND	ND	ND
24	双葉町 上羽島 (リアルタイム ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.11	ND	ND	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.15	ND	ND	ND
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.097	ND	ND	ND
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.17	ND	ND	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.052	0.16	ND	ND	ND
25	浪江町 南津島 (リアルタイム ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.18	ND	ND	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.095	ND	ND	ND
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.053	ND	ND	ND
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.078	ND	ND	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.059	ND	ND	ND
26	南相馬市 横川ダム (リアルタイム ダストモニタ)	H29. 4. 1 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.039	0.063	ND	ND	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.062	ND	ND	ND
		H29. 6. 1 ~ H29. 7. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.073	ND	ND	ND
		H29. 7. 1 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.088	ND	ND	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.078	ND	ND	ND







No.	地点名	採取期間	核種濃度 (mBq/m <sup>3</sup> )																	
			<sup>51</sup> Cr	<sup>51</sup> Mn	<sup>58</sup> Co	<sup>59</sup> Fe	<sup>60</sup> Co	<sup>92</sup> Zr	<sup>96</sup> Nb	<sup>100</sup> Ru	<sup>134</sup> Cs	<sup>137</sup> Cs	<sup>144</sup> Ce							
33	富岡町 夜の森 (ダストサンブラー)	H29. 3. 31 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.28	ND	ND	ND
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.18	ND	ND	ND
		H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
34	大熊町 みなみだい 南台 (ダストサンブラー)	H29. 3. 31 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.20	ND	ND	
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.22	ND	ND	
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.28	ND	ND	
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.36	ND	ND	
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.23	ND	ND	
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.19	ND	ND	
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.39	ND	ND	
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.51	ND	ND	
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.53	ND	ND	
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.19	ND	ND	
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.20	ND	ND	
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.38	ND	ND	
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.33	ND	ND	
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.43	ND	ND	
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.43	ND	ND	
		H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.31	ND	ND	
		H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.56	ND	ND	
		H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.81	ND	ND	
		H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.91	ND	ND	
		H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.99	ND	ND	
		H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.81	ND	ND	
H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.41	ND	ND			



No.	地点名	採取期間	核種濃度 (mBq/m <sup>3</sup> )																		
			<sup>51</sup> Cr	<sup>51</sup> Mn	<sup>58</sup> Co	<sup>59</sup> Fe	<sup>60</sup> Co	<sup>92</sup> Zr	<sup>95</sup> Nb	<sup>100</sup> Ru	<sup>134</sup> Cs	<sup>137</sup> Cs	<sup>144</sup> Ce								
35	浪江町 浪江 (ダストサンプラー)	H29. 3. 31 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.18	ND
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.27	ND
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.21
		H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.27		
H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 4. 1 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.030		
H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		

田村市  
滝根  
(簡易型ダスト  
サンプラー)

No.	地点名	採取期間	核種濃度 (mBq/m <sup>3</sup> )																		
			<sup>51</sup> Cr	<sup>51</sup> Mn	<sup>58</sup> Co	<sup>59</sup> Fe	<sup>60</sup> Co	<sup>92</sup> Zr	<sup>95</sup> Nb	<sup>100</sup> Ru	<sup>134</sup> Cs	<sup>137</sup> Cs	<sup>144</sup> Ce								
37	田村市 船引 (簡易型ダスト サンブラー)	H29. 4. 1 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.030	ND	ND	ND		
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.017	ND	ND	ND	
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.037	ND	ND	ND		
H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 4. 1 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.025	ND	ND	ND		
H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.024	ND	ND	ND		
H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.042	ND	ND	ND		
H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 7. 20 ~ H29. 7. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 7. 27 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.018	ND	ND		
H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.087	ND	ND		
H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.027	ND	ND		
H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.023	ND	ND		

田村市  
上  
(簡易型ダスト  
サンブラー)





No.	地点名	採取期間	核種濃度 (mBq/m <sup>3</sup> )																	
			<sup>51</sup> Cr	<sup>54</sup> Mn	<sup>58</sup> Co	<sup>59</sup> Fe	<sup>60</sup> Co	<sup>92</sup> Zr	<sup>95</sup> Nb	<sup>100</sup> Ru	<sup>134</sup> Cs	<sup>137</sup> Cs	<sup>141</sup> Ce							
42	南相馬市 福島県 楢原 (簡易型ダスト サンプラー) *1	H29. 4. 1 ~ H29. 4. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND			
		H29. 4. 6 ~ H29. 4. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
		H29. 4. 13 ~ H29. 4. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 4. 20 ~ H29. 4. 27	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 4. 27 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 5. 2 ~ H29. 5. 11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 11 ~ H29. 5. 18	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 18 ~ H29. 5. 25	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 5. 25 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 1 ~ H29. 6. 8	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 8 ~ H29. 6. 15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 15 ~ H29. 6. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 22 ~ H29. 6. 29	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 6. 29 ~ H29. 7. 6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 6 ~ H29. 7. 13	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
H29. 7. 13 ~ H29. 7. 20	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 7. 20 ~ H29. 7. 22	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 7. 22 ~ H29. 8. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 8. 3 ~ H29. 8. 10	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 8. 10 ~ H29. 8. 17	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 8. 17 ~ H29. 8. 24	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
H29. 8. 24 ~ H29. 8. 31	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		

(注) 1 No. の網掛け部分は東京電力株式会社福島第一原子力発電所から半径5km未満の地域

2 「ND」: 検出限界未満

3 上記の他、人工放射性核種は検出されなかった。

4 <sup>134</sup>Cs及び<sup>137</sup>Csの検出限界値: 連続ダストモニタはおおむね0.01 mBq/m<sup>3</sup>以下、リアルタイムダストモニタはおおむね0.06 mBq/m<sup>3</sup>以下、ダストサンプラー (1週間集じん) はおおむね0.3 mBq/m<sup>3</sup>以下、簡易型ダストサンプラー (1週間集じん) はおおむね0.04 mBq/m<sup>3</sup>以下、簡易型ダストサンプラー (1日集じん) はおおむね0.05 mBq/m<sup>3</sup>以下である。

5 \*1 No. 42楢原の採取期間H29. 7. 20~H29. 7. 22の測定については、簡易型ダストサンプラーの意図せぬ停止により、採取期間が短くなっている。

5-2-3 降下物の核種濃度

No.	地点名	採取期間	核種濃度 (Bq/m <sup>2</sup> (MBq/km <sup>2</sup> ))													
			<sup>51</sup> Cr	<sup>54</sup> Mn	<sup>58</sup> Co	<sup>59</sup> Fe	<sup>60</sup> Co	<sup>95</sup> Zr	<sup>95</sup> Nb	<sup>106</sup> Ru	<sup>134</sup> Cs	<sup>137</sup> Cs	<sup>144</sup> Ce			
1	いわき市 ひきのほさま 久之浜	H29. 3. 31 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.89	4.4	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.0	ND
		H29. 6. 1 ~ H29. 7. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.8	ND
		H29. 7. 4 ~ H29. 8. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.5	ND
		H29. 8. 2 ~ H29. 9. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.1	ND
2	田村市 みやこじ 都路	H29. 4. 6 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.9	19	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	8.8	59	ND
		H29. 6. 1 ~ H29. 7. 4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.8	26	ND
		H29. 7. 4 ~ H29. 8. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.81	5.7	ND
		H29. 8. 2 ~ H29. 9. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.57	2.7	ND
3	富岡町 とみおか	H29. 4. 3 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	12	78	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.6	38	ND
		H29. 6. 1 ~ H29. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.3	31	ND
		H29. 7. 3 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.9	21	ND
		H29. 8. 1 ~ H29. 9. 5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.8	20	ND
4	大熊町 おおくま	H29. 4. 3 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	210	1,400	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	40	270	ND
		H29. 6. 1 ~ H29. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	18	130	ND
		H29. 7. 3 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	12	88	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.3	32	ND
5	双葉町 ふたば	H29. 4. 3 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	69	460	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	20	140	ND
		H29. 6. 1 ~ H29. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	21	150	ND
		H29. 7. 3 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	16	120	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	6.4	46	ND
6	南相馬市 なま	H29. 4. 4 ~ H29. 5. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.2	22	ND
		H29. 5. 1 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.8	12	ND
		H29. 6. 1 ~ H29. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.45	2.8	ND
		H29. 7. 3 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	2.1	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.1	ND
7	浪江町 なみえ	H29. 4. 4 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	16	110	ND
		H29. 5. 2 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.8	35	ND
		H29. 6. 1 ~ H29. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.3	10	ND
		H29. 7. 3 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.3	9.5	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.48	3.8	ND

No.	地点名	採取期間	核種濃度 (Bq/m <sup>2</sup> (MBq/km <sup>2</sup> ))																									
			<sup>51</sup> Cr	<sup>54</sup> Mn	<sup>58</sup> Co	<sup>59</sup> Fe	<sup>60</sup> Co	<sup>90</sup> Zr	<sup>95</sup> Nb	<sup>106</sup> Ru	<sup>134</sup> Cs	<sup>137</sup> Cs	<sup>144</sup> Ce															
8	浪江町 津島 <small>つしま</small>	H29. 4. 3 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND				
		H29. 5. 2 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
		H29. 6. 1 ~ H29. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 7. 3 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
9	葛尾村 柏原 <small>かしわばら</small>	H29. 4. 4 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
		H29. 5. 2 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 6. 1 ~ H29. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 7. 3 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
10	川俣町 山木屋 <small>やまきや</small>	H29. 4. 3 ~ H29. 5. 2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
		H29. 5. 2 ~ H29. 6. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29. 6. 1 ~ H29. 7. 3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 7. 3 ~ H29. 8. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29. 8. 1 ~ H29. 9. 1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

(注) 1 No.の網掛け部分は東京電力株式会社福島第一原子力発電所から半径5km未満の地域

2 「ND」：検出限界未満





試料名	種類 又は 部位	検取 年月日	単位	全71種 放射能 測定値	核 種 濃 度																					天然 核種	
					<sup>60</sup> Cr	<sup>54</sup> Mn	<sup>59</sup> Co	<sup>55</sup> Fe	<sup>60</sup> Co	<sup>95</sup> Zr	<sup>93</sup> Nb	<sup>101</sup> Ru	<sup>134</sup> Cs	<sup>137</sup> Cs	<sup>141</sup> Ce	<sup>3</sup> H	<sup>131</sup> I	<sup>87</sup> Sr	<sup>90</sup> Sr	<sup>239</sup> Pu	<sup>238</sup> U	<sup>241</sup> Am	<sup>244</sup> Cm				
					ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		ND
上 水	純口水	H29. 4. 6	Bq/l Puは mBq/l	/	0.03	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.10				
		H29. 7. 5			0.03	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.10			
		H29. 4. 20			0.03	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
	川俣町	H29. 7. 6	Bq/l Puは mBq/l	/	0.03	ND	ND	ND	ND	ND	ND	ND	ND	0.042	0.056	ND	0.47	ND	0.0014	ND	ND	ND	0.020				
		H29. 4. 7			0.03	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.042	0.056	ND	0.45	ND	ND	ND	ND	0.023			
		H29. 7. 6			0.03	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.042	0.056	ND	0.45	ND	ND	ND	ND	0.022			
	海 水	表面水	第一(第)南放水口付近*3	Bq/l Puは mBq/l	0.03	0.03	ND	ND	ND	ND	ND	ND	ND	0.002	0.020	ND	ND	ND	0.0014	ND	ND	ND	0.007				
						H29. 5. 16	0.04	ND	ND	ND	ND	ND	ND	0.010	0.063	ND	ND	ND	0.0056	ND	0.007	ND	ND	ND	0.007		
						H29. 6. 13	0.03	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.006	0.040	ND	ND	0.0010	ND	ND	ND	ND	
			第一(第)北放水口付近	H29. 7. 10	0.03	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.004	0.035	ND	ND	0.0020	ND	ND	ND	ND			
				H29. 8. 18	0.02	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.008	0.057	ND	ND	0.0025	ND	ND	ND	ND			
				H29. 4. 20	0.03	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.021	0.15	ND	ND	0.0071	ND	ND	ND	ND			
			第一(第)取水口付近 (港湾出入口の外側)	H29. 5. 16	0.03	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.011	0.060	ND	ND	0.0067	ND	0.009	ND	ND			
H29. 6. 13				0.02	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.006	0.066	ND	ND	0.0057	ND	0.007	ND	ND				
H29. 7. 10				0.05	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.016	0.12	ND	ND	0.0050	ND	0.007	ND	ND				
海 水			表面水	第一(第)沖合2km	Bq/l Puは mBq/l	0.03	0.03	ND	ND	ND	ND	ND	ND	ND	0.009	0.067	ND	0.58	ND	ND	ND	ND	ND	ND	0.006		
							H29. 8. 18	0.04	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.009	0.067	ND	ND	ND	ND	ND	ND	0.007
							H29. 4. 20	0.04	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.005	0.037	ND	ND	0.0009	ND	0.009	ND	ND
				夫沢・熊川沖2km (大熊町)	H29. 5. 16	0.03	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.005	0.037	ND	ND	0.0009	ND	0.009	ND	ND		
	H29. 6. 13	0.02			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.005	0.037	ND	ND	0.0011	ND	0.009	ND	ND				
	H29. 7. 10	0.02			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.010	0.07	ND	ND	0.0011	ND	0.009	ND	ND				
	双葉・前田川沖2km (双葉町)	H29. 8. 18		0.02	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.004	0.04	ND	ND	ND	ND	ND	ND	ND	0.006			
		H29. 4. 20		0.02	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.011	0.07	ND	ND	0.0009	ND	0.009	ND	ND	0.007			
		H29. 5. 16		0.02	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.007	0.04	ND	ND	0.0010	ND	0.009	ND	ND	0.007			
	第二(第)南放水口	H29. 8. 21		0.01	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.004	0.031	ND	ND	ND	0.0007	ND	0.009	ND	ND	0.007			
		H29. 5. 10		0.02	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.003	0.024	ND	ND	ND	0.0013	ND	0.009	ND	ND	0.007			
	第二(第)北放水口	H29. 5. 10		0.02	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.018	0.05	ND	ND	ND	0.0011	ND	0.009	ND	ND	0.007			
		H29. 8. 21		0.01	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.005	0.037	ND	ND	ND	0.0011	ND	0.009	ND	ND	0.007			



試料名	種類 又は 部位	採取地点番号 及び採取地点名	採取 年月日	単位	全γ- 放射能 測定値	核 種 濃 度														天然 核種							
						<sup>60</sup> Cr	<sup>51</sup> Mn	<sup>58</sup> Co	<sup>59</sup> Fe	<sup>60</sup> Co	<sup>95</sup> Zr	<sup>95</sup> Nb	<sup>100</sup> Ru	<sup>134</sup> Cs	<sup>137</sup> Cs	<sup>141</sup> Ce	<sup>3</sup> H	<sup>131</sup> I	<sup>87</sup> Sr		<sup>90</sup> Sr	<sup>239</sup> Pu	<sup>240</sup> Am	<sup>241</sup> Am	<sup>244</sup> Cm		
松 葉	11	葛尾村 柏原 <sup>11</sup>	E29. 6.12	Bq/kg生	／	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	／	／	／	53					
			E29. 9.11		／	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	／	／	／	68			
	E29. 6. 5	／	ND		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	54			
	E29. 9. 4	／	ND		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	38		
	E29. 6.13 E29. 9.11	／	ND		ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	71	
14	飯沼村 長泥 <sup>14</sup>	E29. 6.13	／	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	83	
		E29. 9.11	／	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	71	
		E29. 6.13	／	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	90	
15	川原町 山木屋 <sup>15</sup>	E29. 6.13	／	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	67
		E29. 9.11	／	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	57

(注) 1 陸土及び松葉のNo.の網掛け部分は東京電力株式会社福島第一原子力発電所から半径5km未満の地域、海水及び海底土のNo.の網掛け部分は東京電力株式会社福島第一原子力発電所の取水口付近

2 [ND]: 検出限界未満 「/」: 対象外核種 「—」: 欠測

3 第一(発): 東京電力福島第一原子力発電所 第二(発): 東京電力福島第二原子力発電所

4 上記の他、人工放射性核種は検出されなかった。

5 \*1 水道未復旧のため試料を採取できず、欠測となった。

6 \*2 事故前の採取地点である富岡町役場が水道未復旧であり、代替地点として富岡南配水池で採取したため、測定値については参考値扱いとする。

7 \*3 震災直前まで採取していた場所における試料採取が困難と判断したため、敷地境界の南側から採取した。



5-3-2 大気浮遊じん核種濃度 (比較対照地点)

No.	地点名	採取期間	核種濃度 (mBq/m <sup>3</sup> )																	
			<sup>51</sup> Cr	<sup>54</sup> Mn	<sup>55</sup> Co	<sup>59</sup> Fe	<sup>60</sup> Co	<sup>95</sup> Zr	<sup>95</sup> Nb	<sup>106</sup> Ru	<sup>134</sup> Cs	<sup>137</sup> Cs	<sup>144</sup> Ce							
1	福島市 (簡易型ダスト サンブラー)	H29.4.6 ~ H29.4.7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND		
		H29.5.8 ~ H29.5.9	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.053	
		H29.6.5 ~ H29.6.6	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.094
		H29.7.6 ~ H29.7.7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.8.14 ~ H29.8.15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
2	会津若松市 (簡易型ダスト サンブラー)	H29.4.11 ~ H29.4.12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.5.1 ~ H29.5.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.6.6 ~ H29.6.7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.7.6 ~ H29.7.7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.8.3 ~ H29.8.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
3	郡山市 (簡易型ダスト サンブラー)	H29.4.4 ~ H29.4.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.5.10 ~ H29.5.11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.6.14 ~ H29.6.15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.7.4 ~ H29.7.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.8.1 ~ H29.8.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
4	白河市 (簡易型ダスト サンブラー)	H29.4.11 ~ H29.4.12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.5.1 ~ H29.5.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.030
		H29.6.6 ~ H29.6.7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.7.6 ~ H29.7.7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.8.3 ~ H29.8.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
5	相馬市 (簡易型ダスト サンブラー)	H29.4.4 ~ H29.4.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.5.10 ~ H29.5.11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.034
		H29.6.14 ~ H29.6.15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.7.4 ~ H29.7.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.8.1 ~ H29.8.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
6	伊達市 (簡易型ダスト サンブラー)	H29.4.4 ~ H29.4.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.5.10 ~ H29.5.11	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.041
		H29.6.14 ~ H29.6.15	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.7.4 ~ H29.7.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.8.1 ~ H29.8.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.039
7	南会津町 (簡易型ダスト サンブラー)	H29.4.11 ~ H29.4.12	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.5.1 ~ H29.5.2	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.6.6 ~ H29.6.7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.051
		H29.7.6 ~ H29.7.7	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.8.3 ~ H29.8.4	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

(注) 1 「ND」：検出限界未満 「-」：欠測

2 上記の他、人工放射性核種は検出されなかった。

3 ろ紙の灰化処理はせず、ろ紙を直接18容器で測定した。

4 <sup>134</sup>Cs及び<sup>137</sup>Csの検出限界値：簡易型ダストサンブラー（1週間集じん）はおおむね0.04 mBq/m<sup>3</sup>以下である。

5-3-3 大気中水分のトリチウム濃度 (比較対照地点)

No.	地点名	採取期間	トリチウム濃度		備考
			大気中濃度 (mBq/m <sup>3</sup> )	(参考値) 捕集水濃度 (Bq/l)	
1	福島市 方木 <sup>ほうき</sup> 田	H29.4.3 ~ H29.5.1	6.0	0.98	大気中水分量 (g/m <sup>3</sup> ) 6.1
		H29.5.1 ~ H29.6.1	6.2	0.61	10
		H29.6.1 ~ H29.7.3	14	1.0	13
		H29.7.3 ~ H29.8.1	18	0.91	20
		H29.8.1 ~ H29.9.1	ND	ND	18

(注) 「ND」：検出限界未満

5-3-4 降下物の核種濃度 (比較対照地点)

No.	地点名	採取期間	核種濃度 (Bq/m <sup>2</sup> (MBq/km <sup>2</sup> ))																
			<sup>51</sup> Cr	<sup>54</sup> Mn	<sup>58</sup> Co	<sup>59</sup> Fe	<sup>60</sup> Co	<sup>95</sup> Zr	<sup>95</sup> Nb	<sup>106</sup> Ru	<sup>134</sup> Cs	<sup>137</sup> Cs	<sup>144</sup> Ce						
1	福島市 芳木田	H29.4.3 ~ H29.5.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	
		H29.5.1 ~ H29.6.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.6.1 ~ H29.7.3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.7.3 ~ H29.8.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.8.1 ~ H29.9.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.19	1.4	ND
2	三春町 深作	H29.4.3 ~ H29.5.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.5.1 ~ H29.6.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.6.1 ~ H29.7.3 <sup>*1</sup>	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
		H29.7.3 ~ H29.8.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
		H29.8.1 ~ H29.9.1	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

(注) 1 「ND」: 検出限界未満 「/」: 対象外核種

2 上記の他、人工放射性核種は検出されなかった。

3 \*1 前処理中に、試料の損失があったため、欠測とする。残渣料の測定において、Cs-134はND、Cs-137は1.5Bq/m<sup>2</sup>であった。

5-3-5 環境試料中の核種濃度（比較対照地点）

試料名	種類 又は 部位	採取地点番号 及び採取地点名	採取 年月日	単位	全α-γ 放射能 測定値	核種濃度																	天然 核種						
						<sup>51</sup> Cr	<sup>54</sup> Mn	<sup>58</sup> Co	<sup>59</sup> Fe	<sup>60</sup> Co	<sup>95</sup> Zr	<sup>96</sup> Nb	<sup>106</sup> Ru	<sup>125</sup> Sb	<sup>137</sup> Cs	<sup>137</sup> Cs	<sup>144</sup> Ce	<sup>3</sup> H	<sup>131</sup> I	<sup>90</sup> Sr	<sup>90</sup> Sr	<sup>238</sup> Pu	<sup>239/240</sup> Pu	<sup>241</sup> Am	<sup>244</sup> Cm	<sup>40</sup> K			
陸土	表土	1 福島市 荒井	H29. 5. 24	Bq/kg乾	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	120	830	ND	/	/	2.8	0.02	0.70	0.26	ND	220				
		2 郡山市 蓬新町	H29. 5. 18			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	280	2,000	ND	/	/	0.53	ND	0.04	/	/	360		
		3 いわき市 川宿町	H29. 5. 18			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	290	2,000	ND	/	/	8.5	0.02	0.18	/	/	320		
		4 白河市 天音産声	H29. 5. 16			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	130	930	ND	/	/	2.4	0.01	0.41	/	/	430		
		5 相馬市 中村	H29. 5. 18			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	640	4,500	ND	/	/	2.8	ND	0.43	/	/	340		
		6 会津若松市 一葉町	H29. 5. 17			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	33	240	ND	/	/	0.20	ND	ND	0.62	/	/	790	
		7 南会津町 糸沢	H29. 5. 17			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	9.7	85	ND	/	/	1.2	ND	ND	ND	/	/	280	
上水	蛇口水	1 福島市 芳木田	H29. 4. 4	Bq/l PULchmBq/l Bq/l	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.007	ND	0.40	/	/	/	/	/	ND			
		2 会津若松市 追手町	H29. 4. 11			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.3	27	ND	/	/	/	/	/	/	/	0.048		
松葉	二年葉	1 福島市 杉葉町	H29. 5. 18	Bq/kg生	/	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.9	14	ND	/	/	/	/	/	/	/	/	75			
		2 郡山市 藤山	H29. 8. 24			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	4.1	28	ND	/	/	/	/	/	/	/	94		
		3 白河市 南登り町	H29. 8. 24			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.95	7.6	ND	/	/	/	/	/	/	/	/	65	
		4 会津若松市 城東町	H29. 5. 16			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	5.1	ND	/	/	/	/	/	/	/	120	
		5 南会津町 永田	H29. 8. 28			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	3.6	ND	/	/	/	/	/	/	/	77	
																			0.86	ND	/	/	/	/	/	/	/	/	80
																			ND	ND	/	/	/	/	/	/	/	/	95
															ND	ND	/	/	/	/	/	/	/	/	56				
															ND	ND	/	/	/	/	/	/	/	/	68				

(注) 1 (ND)：検出限界未満 「/」：対象外核種



5-4 試料採取時の付帯データ集  
(原子力発電所周辺等環境放射能測定)

1 上水

No.	採取地点名	採取年月日	気温 (°C)	水温 (°C)	pH
1	いわき市	H29.4.17	18.5	12.0	7.8
		H29.7.4	26.1	23.0	7.8
2	田村市	H29.4.7	14.9	9.5	7.6
		H29.7.4	21.8	22.5	7.7
3	広野町	H29.4.7	20.5	11.0	7.9
		H29.7.5	30.2	24.0	8.1
4	檜葉町	H29.4.7	16.5	12.0	7.9
		H29.7.5	26.1	24.3	8.0
5	富岡町	H29.4.17	15.3	14.2	7.8
		H29.7.5	28.6	22.8	7.8
6	川内村	H29.4.7	16.3	14.5	8.0
		H29.7.4	23.6	18.6	8.0
7	大熊町	—	—	—	—
8	双葉町	—	—	—	—
9	浪江町	H29.4.6	21.0	14.0	7.8
		H29.7.5	29.1	26.0	7.7
10	葛尾村	H29.4.7	16.6	14.3	7.8
		H29.7.6	27.5	21.8	7.9
11	南相馬市	H29.4.6	16.8	13.5	7.7
		H29.7.5	24.3	24.5	7.5
12	飯館村	H29.4.20	17.8	12.0	8.0
		H29.7.6	27.1	22.8	8.0
13	川俣町	H29.4.7	18.5	13.5	7.9
		H29.7.6	26.3	23.0	7.9

2 海水

No.	採取地点名	採取年月日	気温 (°C)	水温 (°C)	pH	Cl <sup>-</sup> (%)
1	第一(発)南放水口付近	H29.4.20	13.3	9.4	8.2	19
		H29.5.16	15.0	14.1	8.2	18
		H29.6.13	15.0	14.8	8.2	17
		H29.7.10	20.0	19.8	8.1	18
		H29.8.18	24.0	24.0	8.2	16
2	第一(発)北放水口付近	H29.4.20	13.0	9.6	8.2	18
		H29.5.16	14.0	13.9	8.2	18
		H29.6.13	14.9	15.0	8.2	18
		H29.7.10	20.0	19.2	8.1	18
		H29.8.18	24.0	23.4	8.2	16
3	第一(発)取水口付近 (港湾出入口の外側)	H29.4.20	13.0	9.8	8.2	19
		H29.5.16	14.5	14.2	8.2	18
		H29.6.13	14.4	14.7	8.2	18
		H29.7.10	20.0	18.6	8.1	18
		H29.8.18	24.0	23.4	8.2	16
4	第一(発)沖合2km	H29.4.20	11.1	9.4	8.2	18
		H29.5.16	14.0	13.8	8.2	18
		H29.6.13	14.2	14.9	8.2	18
		H29.7.10	21.0	19.4	8.1	18
		H29.8.18	23.0	23.3	8.2	16
5	夫沢・熊川沖2km	H29.4.20	11.0	9.6	8.2	19
		H29.5.16	14.0	13.6	8.2	17
		H29.6.13	14.7	14.8	8.1	18
		H29.7.10	21.0	20.1	8.1	18
		H29.8.18	23.0	23.5	8.2	16
6	双葉・前田川沖2km	H29.4.20	11.1	9.7	8.2	18
		H29.5.16	13.8	13.8	8.2	18
		H29.6.13	15.0	15.4	8.2	18
		H29.7.10	21.0	19.3	8.1	18
		H29.8.18	23.0	23.3	8.2	16
7	第二(発)南放水口	H29.5.10	15.5	12.0	8.1	19
		H29.8.21	26.0	24.0	7.7	18
8	第二(発)北放水口	H29.5.10	15.0	13.0	8.2	19
		H29.8.21	27.4	24.0	7.7	17

(比較対照地点環境放射能測定)

1 上水

No.	採取地点名	採取年月日	気温 (°C)	水温 (°C)	p H
1	福島市	H29. 4. 14	19. 8	8. 3	7. 4
2	会津若松市	H29. 4. 11	10. 0	11. 5	7. 2